

CORRIGENDUM -5



रामागुण्डम फर्टिलाइजर्स एण्ड केमिकल्स लिमिटेड

E-Tender No – RFCL- 2025-195

CLARIFICATIONS

“Lining up of Contract FOR Implementation of Zero Liquid Discharge (ZLD) AT RFCL PLANT, RAMAGUNDAM (TELANGANA). [E-Tender No-RFCL- 2025-195]”

Tender Ref: PNMM/PC211/E/002/81 Dated: 15.10.2025]

Following Clarifications to above mentioned tender is hereby authorized:

ANNEXURE-3 dated: 21.11.2025

TENDER SCHEDULE:

<i>Sr. No.</i>	<i>Tender Stage</i>	<i>Date & Time</i>
1	Start Tender Document Download	15.10.2025 at 11:00 hrs.
2	End Tender Document Download	21.11.2025 at 23:00 hrs.
3	Due/ last date of submission Bids	21.11.2025 at 23:30 hrs.
4	Techno-commercial Bids Opening	21.11.2025 at 23:59 hrs.
5	Price Bid Opening	To be intimated

All other terms & conditions of tender document remain unaltered. For further details, visit website: <https://rfcl.co.in/opentender.php> and <https://www.tenderwizard.in/RFCL>. Any Corrigendum / Addendum (s) to this Notice shall be published on RFCL's website / e-tender portal only. The tenders will be submitted online on the web site <https://www.tenderwizard.in/RFCL> only.

For & behalf of RFCL

(Shashi Prakash)
Chief. Manager (Contracts & Procurement)



IMPLEMENTATION OF ZERO LIQUID DISCHARGE (ZLD) UNIT AT RFCL, RAMAGUNDAM
NIT NO : PNMM/PC211/E/002



ANNEXURE No.: 3 dated 21.11.2025


Sl. No.	Reference of Bidding Document				Existing Clause	Amended Clause	Amendment type M/D/A
	Vol-II/ Sec	Page No.	Clause No.				
PART I, COMMERCIAL							
1	CORRIGENDUM -1	78 of 87	Point No. 174 of PRE-BID QUERIES RESOLUTION (SET-1)	<div><div><div>174</div><div>BOQ & PNMM/PC211/E/002/P-II/Sec-10</div><div>25 of 2315</div><div>of Recommended Spares</div><div>SP-4 (TWO) YEARS RECOMMENDED SPARES</div><div>Prices quoted for One (1) Year O&M spares at SP-4 shall not be considered for the evaluation purpose.</div></div><div><div>Bidder understand it is typo error, bidder has to quote for year o&m recommended spares and same will not considered for evaluation. Please confirm.</div><div>NIT prevails</div><div>Not a typographical error.</div><div>Two years Recommended spares shall be provided by the contractor as per Spares List (PC211/E/002/P-II/Sec-9.0) of the tender and shall be part of LSTK Price.</div><div>Lump sum Price for one year Operation & Maintenance services includes all spares for ZLD Unit including Control System for 01 year.</div><div>(Reply as per CORRIGENDUM -1)</div></div></div> <td><div><div>Two years Recommended spares as quoted in SP-4 shall not be considered for evaluation.</div><div>Price for One Year O&M Spares shall be included in the price quoted at sr. No. 1.02 of SP-0. The same shall be considered for evaluation.</div></div></td> <td>M</td>	<div><div>Two years Recommended spares as quoted in SP-4 shall not be considered for evaluation.</div><div>Price for One Year O&M Spares shall be included in the price quoted at sr. No. 1.02 of SP-0. The same shall be considered for evaluation.</div></div>	M	



IMPLEMENTATION OF ZERO LIQUID DISCHARGE (ZLD) UNIT AT RFCL, RAMAGUNDAM
NIT NO : PNMM/PC211/E/002



ANNEXURE No.: 3 dated 21.11.2025

Sl. No.	Reference of Bidding Document				Existing Clause	Amended Clause	Amendment type M/D/A
	Vol-I/ Sec	Page No.	Clause No.				
1	CORRIGENDUM -2	61 of 70	Point No. 144 of PRE-BID QUERIES RESOLUTION (SET-2)		 <p>Bidder to indicate power Consumption per day (24 hrs) for required capacity as per Specifications in SP-03.</p> <p>Price loading/ penalty shall remain as per NIT terms and conditions (Part I / Sec 1.0 Cl. 29.0 and Part II / Sec 7.0).</p> <p>(Reply as per CORRIGENDUM -2)</p>	<p>Price loading/ penalty on guaranteed chemical and power consumption shall remain as per NIT terms and conditions.</p> <p>Bidder to furnish chemical and power consumption for one year in SP-03.</p>	M

M: MODIFICATION, A: ADDITION, D: DELETION